



Notes:

1. Edge metal should be designed for wind resistance in accordance with the applicable edition of ASCE 7. Additional requirements apply for guarantee coverage of attachment to insulated metal wall panels. Contact coldstorage.assistance@gaf.com for details.
2. For steel roof decks: Fill steel deck flutes with closed cell spray foam insulation prior to the installation of above deck insulation a minimum of 12" [305 mm] from face of wall.

LEGEND

	ADHESIVE
	SEALANT

Preparation of I.M.P. Walls for Edge Termination

Roof Area:
Field of Roof

Detail No:

Issue Date:
11/13/2023

Scale:
N.T.S.

237